

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 3295-0577:001

Page 1 of 1

CATEGORY: Fire-Rated Door

LISTEE: Republic Builders Products, PO Box 580, McKenzie TN 38201
Contact: Craig J Ordmandy (731) 352-3383*

DESIGN: Model 634 series and Models DE420, DE418 and DE416. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, rating and UL label.

APPROVAL: Listed as a 3hour fire-rated door when installed in a frame approved for the wall construction and the door is equipped with fire-rated hardware.

NOTE: Formerly 3375-0577:001

*Rev. 06-10-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 10, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager